

Addendum

REQUEST FOR INFORMATION

August 30, 2019

QUESTION 1 of 2

Referencing the “Jordan Lions Park Pool Requirements”, Items 5, 6, 7, 8, 12, 13, can you confirm if the intent of your specification is to have all wall and overflow gutter stainless steel components in the submittals be of 12 gauge T316L Marine Grade Stainless Steel, and without protective coatings or coverings (such as plastics or PVC lamination) that may obscure the steel itself?

RESPONSE

Yes, this in fact correct as we do not want lamination of plastics that may damage the stainless steel over time.

QUESTION 2 of 2

Referencing the “Jordan Lions Park Pool Requirements”, Item 10 “The pool system shall employ no PVC fittings that are not absolutely required (such as inlets, gutter grating, gutter dropouts, main drain sumps or main drain covers), or coping, grab edges, or other feature and shall only employ GPM Polymer or HDPE materials. The manufacturer will warranty these GPM Polymer or HPDE materials for a minimum of 15 years.” Can you please confirm if a change from GPM Polymer or HDPE to T316L Stainless Steel pool grab edge is acceptable to the project?

RESPONSE

Yes, an upgrade would be acceptable. Our requirements remain as stated. We would discuss and entertain upgrades to the coping and grab edges if the awarded contractor can provide it at no additional cost.